



Validation of Electrical Safety Testers

Ensuring the Reliability of Regulatory Test Results

The validation process for electrical safety test equipment is often overlooked by manufacturers. However, performing regular verification is essential to ensure that safety testers can accurately detect product failures and maintain the validity of regulatory compliance testing. While establishing a test validation process may appear complex, the right equipment and a standardized procedure can make the entire process simple, clear, and easy to implement.

Why Validation Is Necessary

International safety certification organizations, including Underwriters Laboratories (UL), CSA Group (CSA), VDE Testing and Certification Institute (VDE), TÜV SÜD (TÜV), and International Electrotechnical Commission (IEC), have established safety standards to ensure electrical products meet required safety requirements.

The purpose of electrical safety testing is to verify that electronic products do not pose electrical shock hazards to end users. However, the reliability of test results depends on the accuracy and proper operation of the test equipment used. In manufacturing environments, electrical safety testers may experience internal damage due to prolonged use or external factors. Even without visible signs of failure, such issues can cause inaccurate results in insulation resistance, leakage current, and dielectric withstand tests.

Therefore, regular validation of electrical safety test equipment ensures reliable operation, maintains compliance with NRTL (Nationally Recognized Testing Laboratory) requirements, and improves the reliability and regulatory compliance of electrical safety test results.

According to the UL Mark Integrity Program document, Equipment Used for UL/C-UL/ULC Mark Follow-Up Services, all measuring and test equipment must undergo regular functional checks.

The document clearly states:

Inspection, Measuring, and Test Equipment (IMTE) used to determine product compliance with UL requirements shall be functionally checked by the user on a daily basis to ensure proper operation. If the equipment is not used every day, a functional verification shall be performed before each use. [1]

Associated Research

28105 N. Keith Drive Lake Forest, IL 60045 USA
T. 1-847-367-4077 www.arisafety.com

This requirement highlights the importance of maintaining and verifying the proper operation of measuring equipment, including electrical safety testers. It also serves as a key basis for requiring regular validation of electrical safety test equipment to ensure reliable test performance and continued compliance with safety requirements.

Common Electrical Safety Tests: Overview of Key Test Methods

To ensure the safety of electrical products during operation, products must undergo a series of rigorous safety tests. Electrical safety testing is primarily used to verify the electrical integrity and safety performance of a product, ensuring that it does not present electrical hazards to users under normal operating conditions or specified test conditions. Common electrical safety tests include:

- Ground Bond / Continuity Test
- Dielectric Withstand / High Potential (Hipot) Test
- Insulation Resistance Test
- Leakage Current Test

Each test has its own specific test conditions and acceptance criteria, designed to identify different types of potential electrical safety risks. Table 1 summarizes common dielectric withstand test settings specified in various NRTL standards.

Standard / Harmonized Standard	Testing Type	DIELECTRIC WITHSTAND		
		Test Voltage	Max I.	Test Time
IEC/UL 60601-1 3rd Edition Medical Electrical Equipment	Performance	500 – 4000 VAC or 707 – 5656 VDC	No Breakdown	60 s
	Production	1000 – 3000 VAC		1 or 60 s
IEC 61730-2 UL 1703 Photovoltaic Modules & Panels	Performance	1000 VAC + 2 x rated V or 2000 VAC + 4 x rated V	50 uA	60 s
	Production	1000 VAC + 2 x rated V or (1000 VDC + 2 x rated V) X 120%	50 uA	1 or 60 s
IEC 60335-1 Household Electrical Appliances	Performance	500 – 2400 VAC x rated V + 2400 VAC	No Breakdown	60 s
	Production	400 – 2500 VAC	5-30 mA	1 s
UL 60335-1 Household Electrical Appliances	Performance	500V – 2400 VAC x rated V + 2400 VAC	No Breakdown	60 s
	Production	400 – 2500 VAC	5-30 mA	1 s

Table 1 Common NRTL Hipot Parameters

Ground Bond Test

The Ground Bond Test or Ground Continuity Test, is primarily used to verify the integrity and reliability of the protective earth (Safety Ground) connection in electrical equipment.

When a product experiences abnormal conditions, such as component failure or insulation breakdown, the protective ground must be capable of carrying the resulting fault current and providing a low-impedance path to earth. This allows the fault current to flow safely to ground, enabling protective devices such as fuses to operate promptly and disconnect power, reducing the risk of electric shock and equipment damage.

To ensure this protection mechanism functions properly, all accessible conductive metal parts of the product must maintain reliable continuity with the grounding pin or grounding terminal.




Figure 1: Circuit for a Ground Bond Test

Figure 1 illustrates a typical Ground Bond test circuit.** During the test, the Ground Bond tester applies a test current through the product's grounding pin and uses the chassis or exposed metal parts as the return path. While the test current is applied, the instrument measures the voltage drop across the protective ground circuit and calculates the ground path impedance to evaluate whether the protective grounding continuity meets safety requirements.

Common Ground Bond test conditions include a test current of 10–30 A, a ground circuit impedance limit of 100–200 mΩ, and a voltage drop typically not exceeding 6–12 V.

Dielectric Withstand Test

The Dielectric Withstand Test, commonly known as the High Potential (Hipot) Test or Hi-Pot Test, is a critical electrical safety test used to evaluate the insulation performance of electrical products.

The purpose of this test is to apply a test voltage higher than the product's normal operating voltage to the insulation system, verifying whether the insulation materials have sufficient withstand capability. If the insulation system can withstand a significantly higher voltage for a specified period without dielectric breakdown or failure, it indicates that the product is expected to operate safely under its rated voltage conditions, reducing the risk of electric shock caused by insulation failure.

The Dielectric Withstand Test is a widely used electrical safety test. In addition to identifying weak points within an insulation system, it can detect various potential safety issues, including excessive leakage current, manufacturing defects such as pinholes and scratches, insufficient spacing between conductors and grounded parts, and insulation degradation caused by environmental factors. Due to its broad detection capability and effectiveness in identifying insulation-related defects, the Dielectric Withstand Test is required by most Nationally Recognized Testing Laboratories (NRTLs) as a mandatory 100% production line safety test.

The principle of the Dielectric Withstand Test is to apply a high voltage between the product's current-carrying conductors and conductive enclosure, with the enclosure serving as the return path for current. During the test, the Hipot tester measures the leakage current flowing through the insulation system to determine whether the product's insulation performance meets safety requirements.

The test voltage applied during a Dielectric Withstand Test varies depending on the applicable safety standard. However, a commonly used calculation method is based on the following formula:

$$\text{Test Voltage} = 2 \times \text{Rated Product Voltage} + 1000 \text{ V}$$

The Dielectric Withstand Test circuit can typically be represented using an equivalent circuit model, which consists primarily of the device parasitic capacitance (Device Capacitance, C), insulation resistance (Insulation Resistance, R_L), and a small amount of contact resistance (Contact Resistance, R_A), as illustrated in Figure 2.

o




Figure 2: Dielectric Withstand Circuit Diagram



Insulation Resistance Test

The Insulation Resistance (IR) Test is not always a mandatory electrical safety test required by safety standards; however, it provides valuable quantitative data for evaluating a product's insulation performance. Unlike the Dielectric Withstand Test, which primarily measures leakage current, the Insulation Resistance Test directly measures the insulation resistance value of a product, providing a more straightforward assessment of insulation quality and degradation.

The Insulation Resistance Test directly measures the resistance of the insulation system. According to safety certification requirements, the test voltage is typically set at 500 VDC or 1000 VDC. Since this test applies a direct current (DC) voltage, once the capacitive components within the insulation system are fully charged, the leakage current flowing through the insulation is primarily resistive leakage current. This allows the actual insulation resistance value of the insulation system to be determined.

The execution of an Insulation Resistance (IR) Test is similar to that of a Hipot Test. A high voltage is applied to the product's current-carrying conductors, while the return terminal of the test circuit is connected to the product enclosure. For example, when performing an IR Test on a solar panel, the positive and negative terminals are typically shorted together before applying the test voltage, and the return terminal is connected to the metal frame. This method applies electrical stress to the insulation system while the insulation resistance tester measures the leakage current flowing to the exposed metal enclosure, allowing the insulation performance of the product to be evaluated.

The IR Test is commonly used to verify insulation performance after equipment repair or performed after a Hipot Test to confirm that the applied high voltage has not caused damage to the insulation system.

Leakage Current Test

The Leakage Current Test is similar to the Dielectric Withstand Test, as both measure the current flowing through the insulation system of a product, either through the insulation material itself or along the surface of the insulation.

However, there are important differences between the two tests. The Leakage Current Test is performed while the product is operating at its rated voltage or under an upper voltage condition, typically 110% of the rated voltage. In contrast, the Hipot Test applies a high test voltage while the product is not operating normally, in order to evaluate the insulation withstand capability.

Another key difference is the method used to measure leakage current. In a Dielectric Withstand Test, leakage current is measured through a current-sensing resistor located on the return path of the test circuit, as shown in Figure 3.

Associated Research

28105 N. Keith Drive Lake Forest, IL 60045 USA
T. 1-847-367-4077 www.arisafety.com




Figure 3: Hipot Detection Circuits

During a Leakage Current Test, the leakage current is measured through a test network known as a Measuring Device (MD). Figure 4 shows an example of a typical MD configuration.

The purpose of the MD is to simulate human body impedance characteristics, allowing the evaluation of the leakage current that a user may be exposed to when coming into contact with the product under normal operating conditions. The measured value is then used to determine whether the product complies with applicable electrical safety standard requirements.




Figure 4: 60601-1 Measuring Device

Another key difference between the Leakage Current Test and other electrical safety tests is that it includes the verification of fault conditions. These fault conditions are designed to simulate the most severe scenarios that may occur during actual product operation, allowing the safety performance of the equipment under abnormal conditions to be evaluated.

The three most common fault conditions include:

- Opening of the Neutral Circuit
- Reversal of Line Polarity
- Opening of the Ground Circuit

Figure 5 illustrates a typical Leakage Current Measurement Network.




Figure 5: Leakage Current Configuration

Switch S1 represents the simulation of a Neutral Fault Condition, switch S2 represents the simulation of Polarity Reversal, and switch S3 represents the simulation of an Open Ground Condition.

The purpose of performing tests under different fault configurations is to accurately evaluate the leakage current that a user may be exposed to when a product encounters abnormal conditions during operation. By simulating a range of potential fault scenarios, the safety performance of the product under non-normal operating conditions can be verified.

If the measured leakage current remains within an acceptable low range under all applicable fault conditions, it provides reasonable assurance that the product can continue to operate safely throughout its service life without presenting an electric shock hazard to users.

The acceptance criteria for Leakage Current Tests vary significantly depending on the applicable safety standard. One of the most common Leakage Current Test requirements is based on the third edition of the IEC 60601-1 standard for medical electrical equipment. According to this standard, the Leakage Current Test must be performed at 110% of the rated line voltage using a Measuring Device (MD, Figure 4) that complies with IEC 60601-1 requirements. The acceptable leakage current limits vary depending on the product classification and application conditions, with allowable limits ranging from 10 μ A to 10 mA.

The Importance of Test Verification



Dielectric Withstand, Ground Bond, Insulation Resistance, and Leakage Current test functions are commonly integrated into multi-function test systems or a single comprehensive electrical safety tester. Since these instruments perform multiple safety tests, it is critical to verify that the tester can correctly identify failures when measured values exceed the specified limits. In high-volume production environments, a malfunctioning test system may allow products that should fail the safety test to pass inspection, resulting in potential safety risks.

Therefore, verifying all test functions ensures that the safety tester operates correctly within the specified test conditions and parameter limits, providing reliable safety test results. According to UL-related procedures, any test function that uses measurement results to determine whether a product complies with electrical safety requirements must be verified.

A case that highlights the importance of test verification is damage to the measurement circuit of a Hipot tester.

Most Hipot testers are not designed to withstand an external voltage being applied to the return terminal of the instrument. In actual production line environments, incidents have occurred where operators accidentally applied the mains voltage to the return terminal of the Hipot tester due to improper operation. To protect other internal electronic components of the Hipot tester, a Transient Voltage Suppressor (TVS) is typically installed in the instrument's return path to absorb or limit abnormal transient voltages, as shown in Figure 6.




Figure 6: High Voltage and Return Path with TVS on Return



When an external power voltage is applied to the return terminal, the Transient Voltage Suppressor (TVS) conducts and absorbs or limits the abnormal energy to protect other internal circuits of the instrument. However, if the TVS is damaged due to excessive energy stress, it may fail into a direct short circuit, causing the measurement circuit to be completely bypassed.

Under this condition, when performing a Dielectric Withstand Test, the Hipot tester may measure a leakage current of 0.0 mA and incorrectly determine that the product has passed the test. For a Hipot tester, zero leakage current represents an ideal condition of infinite insulation resistance, causing the instrument to interpret the tested electrical product as meeting insulation safety requirements.

By performing a simple functional verification on the tester, such failures can be immediately detected. This alerts operators to potential abnormalities in the test system and prevents incorrect safety judgments caused by malfunctioning test equipment.

The example above represents only one possible failure scenario. Other potential risks include harsh environmental conditions, such as high temperature and high humidity. Long-term exposure to these conditions may affect the measurement performance and accuracy of test instruments. If the actual accuracy of test equipment deviates significantly beyond the specified measurement tolerance range, products under test may be incorrectly classified as either pass or fail. By performing regular test verification, such as weekly or daily verification of complete product test functions, potential issues within the measurement circuits can be identified immediately. Implementing simple and routine verification procedures can prevent more serious problems from developing and reduce the risk of product recalls. Although establishing a verification process may require additional time and resources initially, the investment is generally worthwhile compared with the potential losses caused by test equipment failure.

Efficient Verification Process for Electrical Safety Test Stations

Routine product safety testing is primarily used to identify potential issues that may create safety risks, including insulation failures, poor grounding, loose connections, component failures, internal grounding abnormalities, unprotected live parts, and excessive leakage current that may result in electric shock hazards. Simply creating short-circuit or open-circuit conditions between test terminals can provide an effective method for confirming that the basic failure detection functions of the test instrument are operating correctly. However, these simple methods cannot identify all potential issues that may exist within the test equipment.

By configuring a simple resistor network and relays, operators can have a convenient method to confirm whether the test equipment is functioning properly. The principle is to use the resistor network to generate specific voltage drops and configure test limits that intentionally trigger failure results, verifying that the instrument's pass/fail judgment function operates correctly.

Associated Research

28105 N. Keith Drive Lake Forest, IL 60045 USA
T. 1-847-367-4077 www.arisafety.com

Furthermore, if the verification network is designed with easy-to-connect interface ports and programmable control capabilities, the verification process can be executed automatically during each validation cycle, improving efficiency and consistency. Providing operators and technicians with a simple and user-friendly verification method increases the likelihood of detecting abnormal measurement conditions before product testing begins. Figure 7 illustrates a Test Box specifically designed for test equipment verification.



Figure 7: Associated Research TVB-2 Test Verification Box

Using the TVB-2 shown in Figure 7 as an example, a simple yet effective verification procedure can be established and performed daily to confirm that electrical safety test equipment is functioning properly.

The verification box consists of a series of resistor components. By selecting specific resistance values, the box can generate expected leakage current levels or simulate designated impedance values. The following examples demonstrate the verification methods for different electrical safety test functions.

For each safety test function, the TVB-2 verification box provides two test terminals: one for simulating a pass condition and the other for simulating a fail condition. This design uses different resistor values connected between each test terminal and the RETURN terminal of the verification box to generate the corresponding test results. The TVB-2 settings for each test item are listed in Table 2.



	ACW	DCW	IR	GC	GB
PASS	2M Ω	2M Ω	4M Ω	500m Ω	50m Ω
FAIL	120k Ω	120k Ω	1M Ω	2 Ω	200m Ω
Instrument Settings	1240V 10mA	2121V 5000uA	500V 2MOhm	1 Ω	30A 100m Ω
Ramp	2s	2s	N/A	N/A	N/A

Table 2: TVB-2 Box Resistance Values and Test Settings

Dielectric Withstand Verification

When the Dielectric Withstand Test voltage is set to 1240 VAC, the FAIL verification circuit uses a 120 k Ω resistor, while the PASS verification circuit uses a 2 M Ω resistor, according to the data in Table 1.

Therefore, the Hipot tester requires two separate verification tests. The first test is the PASS verification test. The Hipot tester should be configured with the following settings:

- Test Voltage: 1240 VAC
- Leakage Current Hi-Limit: 10 mA
- Ramp Up Time: 2 seconds
- Dwell Time: 1 second

During the verification test, connect the high-voltage test lead of the Hipot tester to the PASS terminal in the ACW/DCW section of the TVB-2 verification box, and connect the return test lead to the RETURN terminal of the TVB-2.

Using a simple Ohm's Law calculation, the expected leakage current can be determined to be approximately 620 μ A:

$$\text{Leakage Current} = 1240 \text{ V} / 2,000,000 \Omega = 0.00062 \text{ A}$$

The test result should be correctly identified as PASS. The next step is to perform the FAIL verification test.

The Hipot tester remains configured with the same test parameters used for the PASS verification. The high-voltage test lead is then moved from the PASS terminal to the FAIL terminal in the ACW/DCW section of the TVB-2 verification box.

After performing the test, the expected leakage current should be approximately 10.3 mA. Since this value exceeds the leakage current Hi-Limit setting of the Hipot tester, the test result should be correctly identified as FAIL.

$$\text{Leakage Current} = 1240 \text{ V} / 120,000 \Omega = 0.01033 \text{ A}$$

Associated Research

28105 N. Keith Drive Lake Forest, IL 60045 USA
T. 1-847-367-4077 www.arisafety.com



To comply with the requirements of applicable certification organizations, the test result should be determined as FAIL within 0.5 seconds of the Dwell Time period. If the test does not identify the failure condition within the specified time, it indicates that the test instrument may not be accurately measuring leakage current. In such cases, the equipment should be inspected, repaired, or recalibrated.

Ground Bond Verification

When the Ground Bond Test current is set to 25 A AC, the FAIL verification circuit uses a 200 mΩ resistor, while the PASS verification circuit uses a 50 mΩ resistor, according to the data in Table 1.

Therefore, the Ground Bond tester requires two separate verification tests. The first test is the PASS verification test. The Ground Bond tester should be configured with the following settings:

- Test Current: 25 A AC
- Hi-Limit: 100 mΩ
- Dwell Time: 1 second

During the test, connect the high-current test lead (red lead) of the Ground Bond tester to the PASS terminal in the GB section of the TVB-2 verification box, and connect the return test lead (black lead) to the RETURN terminal of the TVB-2. After performing the test, the expected measured resistance value should be approximately 50 mΩ, and the result should be correctly identified as PASS.

Next, perform the FAIL verification test. The Ground Bond tester remains configured with the same test parameters used for the PASS test. Move the high-current test lead from the PASS terminal to the FAIL terminal in the GB section of the TVB-2 verification box. After performing the test, the expected measured resistance value should be approximately 200 mΩ, and the result should be immediately identified as FAIL.

To comply with the requirements of applicable certification organizations, the test must identify the failure condition within 0.5 seconds of the Dwell Time period. If the test fails to detect the failure condition, the tester may not be accurately measuring the ground circuit impedance. Further analysis of the equipment condition should be performed to determine whether an abnormality exists.

Associated Research

28105 N. Keith Drive Lake Forest, IL 60045 USA
T. 1-847-367-4077 www.arisafety.com



Insulation Resistance Verification

The Insulation Resistance (IR) Test voltage used in this verification example is 500 VDC. According to Table 1, the FAIL verification circuit uses a 4 MΩ resistor, while the PASS verification circuit uses a 1 MΩ resistor.

The Insulation Resistance tester (IR instrument) requires two different verification test conditions.

The first test is the PASS verification test. The IR instrument should be configured with the following settings:

- Test Voltage: 500 VDC
- Low Limit: 2 MΩ
- Ramp Up Time: 2 seconds
- Dwell Time: 1 second

Connect the High Voltage Lead of the IR instrument to the PASS terminal in the IR section of the TVB-2 verification box, and connect the Return Lead to the RETURN terminal of the TVB-2. During the test, the measured resistance value should be approximately 1 MΩ, and the test result should be correctly identified as PASS.

The second test is the FAIL verification test. The IR instrument remains configured with the same test parameters used for the PASS test. The High Voltage Lead is then moved to the FAIL terminal in the IR section of the TVB-2. During the test, the measured resistance value should be approximately 4 MΩ, and the result should be immediately identified as FAIL.

To comply with the requirements of applicable regulatory organizations, the test result must identify the failure condition within 0.5 seconds of the Dwell Time cycle. If the test fails to detect the FAIL condition, it indicates that the equipment may not be accurately detecting insulation resistance changes. Further analysis of the equipment condition should be performed to determine whether an abnormality exists.

Leakage Current Verification

Unlike other electrical safety test verification methods, Leakage Current Test verification does not have a clearly defined verification approach. The TVB-2 verification box does not include dedicated terminals for verifying leakage current measurements. However, the same verification concept can be extended to confirm whether a Leakage Current tester is operating within its specified performance range.

Since products are operated at their rated voltage during Leakage Current Testing, most Leakage Current testers are equipped with a universal power outlet, as shown in Figure 8.



Figure 8: Universal Receptacle Box

A simple fixture can therefore be developed and connected to the power outlet of the Leakage Current tester. Using a standard power plug with two different resistor values connected at the plug terminals provides a simple method for creating a Leakage Current verification fixture.

Under normal polarity conditions, a Leakage Current tester measures the leakage current between Ground and Neutral. Under reversed polarity conditions, it measures the leakage current between Ground and Line. Therefore, different resistor values can be connected between Line and Ground, as well as between Neutral and Ground, to simulate different leakage current conditions for verification.

For example, a test plug can be created for Leakage Current verification:

- Connect a 2 MΩ resistor between Line and Ground
- Connect a 200 kΩ resistor between Neutral and Ground

The first Leakage Current verification test is configured as follows:

- Test Voltage: 120 VAC
- Frequency: 60 Hz
- Leakage Current High Limit: 50 μA
- Polarity: Reverse Polarity
- Dwell Time: 5 seconds

When a 2 MΩ resistor is connected between Line and Ground, the expected leakage current reading should be approximately 60 μA:

$$\text{Leakage Current} = 120 \text{ V} / 2,000,000 \text{ } \Omega = 0.00006 \text{ A}$$

The measured leakage current value should cause the test result to be identified as FAIL. The second test is used to verify whether the Leakage Current tester can correctly detect a failure condition under normal polarity conditions.

The second Leakage Current verification test is configured as follows:

- Test Voltage: 120 VAC
- Frequency: 60 Hz
- Leakage Current High Limit: 550 μ A
- Polarity: Normal Polarity
- Dwell Time: 5 seconds

When a 200 k Ω resistor is connected between Neutral and Ground, the expected leakage current reading should be approximately 600 μ A. Therefore, the test result should be correctly identified as FAIL.

Although a Leakage Current tester contains various internal components, such as relays and switching circuits, the primary verification objective is to confirm that the leakage current detection function can correctly trigger a failure judgment when excessive leakage current is present.

The two verification tests described above can be used to confirm that the Leakage Current tester accurately measures leakage current and correctly identifies failure conditions when the measured value exceeds the specified limit.

Conclusion

With the integration of microprocessor technology into electrical safety test equipment, verification procedures have become increasingly complex. The advancement and integration of new technologies have expanded the level of verification required for modern instruments beyond that of traditional analog equipment.

Electrical safety testers typically include built-in suppressors designed to protect internal circuits. However, damage to these protective components may also cause incorrect measurement results. Performing simple daily verification procedures can help prevent significant issues and additional costs, while reducing the risk of expensive product redesigns or recalls.

Connecting a resistor in series with the output of an electrical safety tester provides a simple method to verify measurement results and confirm that failure detection functions are operating correctly. Using a verification fixture consisting of multiple calibrated resistor values can further improve the completeness and reliability of the verification process.

In addition, microprocessor-controlled safety test equipment typically provides functions for editing and storing test programs. These programs can be configured to include operating instructions and data collection capabilities.

A well-designed verification method provides operators with a simple approach to store verification procedures and perform daily equipment validation. Regular execution of verification processes ensures that all test equipment continues to meet the requirements of NRTL (Nationally Recognized Testing Laboratory) standards.



References: [1] [UL Calibration Requirements: Equipment Used for UL/C-UL/ULC Mark Follow-Up Services](#)

Associated Research

28105 N. Keith Drive Lake Forest, IL 60045 USA
T. 1-847-367-4077 www.arisafety.com